





7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

CF 3x95-6 ТУ У 27.3-00214534-091:2017

Power cables with copper conductors, with impregnated paper insulation, lead-sheathed

Cables are used for laying:

- · in blocks
- · with no risk of mechanical damage in operation

Fire safety code in accordance with ДСТУ 4809:2007: ΠБ100000000

Products of this mark meet the requirements:

· single wire cable flame retardance

TECHNICAL SPECIFICATIONS

| Rated voltage | kV | 6 |
|---|-------|------------------|
| Number and rated area of conductors | mm² | 3 x 95 |
| Insulation thikness between conductors | mm | 4 |
| Insulation thikness of conductor-sheath | mm | 2.95 |
| Sheath thikness | mm | 1.88 |
| Permissible continious current rating * | | |
| by aerial laying | Α | 296 |
| • by burial | Α | 280 |
| Operating temperature range | °C | -50 +50 |
| Minimum bending radius by laying | mm | 555 |
| Level difference along the laying rout, not more than | m | 15 |
| Metal shaeth outer diameter (for reference only) | mm | 34 |
| Rated outer diameter of the cable (for reference) ** | mm | 37 |
| Cable weight (approximate) | kg/km | 5320 |
| Rated factory cable length and gross weight of the delivery | m, t | # 16a: 700 • 4.0 |
| on the drums *** | | |

Notes:

When ordering it is neccesary to agree the factory length of the product with the manufacturer

^{*} Long permissible current loads are calculated for the following conditions: air temperature plus 25 °C, soil temperature plus 15 °C, thermal resistivity of soil 1.2 °K • m/W, laying depth in the soil 0.7 m

^{**} The external diameter may differ from the rated up to \pm 10 %








7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

СГ 3x95-6 ТУ У 27.3-00214534-091:2017

Power cables with copper conductors, with impregnated paper insulation, lead-sheathed



CONSTRUCTION

- 1. Copper multiwire compact conductor
- 2. Impregnated paper insulation
- 3. Cable paper bundle
- 4. Belt insulation
- 5. Conducting paper screen
- 6. Lead sheath

Note: Conductor twisting is not illustrated