



## **ПвПГнг-FRHF 4x150-1 ТУ У 31.3-00214534-069:2012**

Fire resistant power cables with copper conductors, XLPE-insulated, with polymer compound outer sheath, flame-retardant, halogen-free

Cables are used for laying:

- *power supply cable lines of NPP electric equipment, wiring in office premises, which are computerized and intelligent, in kindergartens, schools, hospitals and for cable lines of spectating complexes and sport structures*
- *power supply cable lines of NPP safety system equipment, circuits wiring of fire safety systems (fire alarm circuits, power supply of fire-fighting pumps, lightning of emergency exits and evacuation routes, smoke exhaust and blowing ventilation systems, evacuation elevators); for wiring in hospital surgical wings, emergency and equipment (current collectors) power supply circuits, operating in a fire emergency*

Manufacturing of extruded fire-resistant barrier is possible

Fire safety code in accordance with ДСТУ 4809:2007: ПБ123122080

Products of this mark meet the requirements:

- *single wire cable flame retardance*
- *bunched cable flame retardance category A*
- *toxicity class Tk3 of the combustion products of nonmetallic elements (toxicity index over 120 g/m<sup>3</sup>)*
- *class ДТк1 on smoke-forming ability by smouldering of non-metallic elements (coefficient of smoke formation from 50 to 500 m<sup>2</sup>/kg)*
- *class ДПк2 on smoke-forming ability by combustion (minimum luminous flux more than 60 %)*
- *corrosive class Кк2 of combustion products of non-metallic elements (the number of halogen hydrides less than 150 mg/g, pH more than 4.3, specific conductivity less than 10 μS/mm)*
- *flame-resistant class FE180 under fire conditions with a temperature not less than 750 °C*



## ПВПГнг-FRHF 4x150-1 ТУ У 31.3-00214534-069:2012

Fire resistant power cables with copper conductors, XLPE-insulated, with polymer compound outer sheath, flame-retardant, halogen-free

### TECHNICAL SPECIFICATIONS

|  |                 |                                    |
|--|-----------------|------------------------------------|
| Rated voltage  | kV              | 1                                  |
| Number and rated area of conductors                                      | mm <sup>2</sup> | 4 x 150                            |
| Phase insulation thickness   | mm              | 1.4                                |
| Permissible continuous current rating (AC of industrial frequency) *     |                 |                                    |
| • by aerial laying   | A               | 406                                |
| Maximum permissible conductor temperature                                |                 |                                    |
| • Continuous   | °C              | +90                                |
| • in emergency operation   | °C              | +130                               |
| • at short circuit   | °C              | +250                               |
| Operating temperature range  | °C              | -50 ... +50                        |
| Minimum bending radius by laying   | mm              | 360                                |
| Rated outer diameter of the cable (for reference) **                     | mm              | 48                                 |
| Cable weight (approximate)   | kg/km           | 6590                               |
| Rated factory cable length and gross weight of the delivery on the drums | m, t            | # 18: 500 • 3.8<br># 20: 800 • 5.9 |

#### Notes:

When ordering it is necessary to agree the factory length of the product with the manufacturer

\* Long permissible current loads are calculated during operation in four-wire networks with load in all the conductors for the following conditions: air temperature plus 25 °C, soil temperature plus 15 °C, thermal resistivity of soil 1.2 °K·m/W, laying depth in the soil 0.7 m

\*\* The external diameter may differ from the rated up to ± 10 %

### CONSTRUCTION

1. Copper multiwire compact conductor
2. Fire-resistant barrier  
*Note: Manufacturing of extruded fire-resistant barrier is possible*
3. XLPE insulation
4. PVC compound bundle
5. Halogen-free polymer compound inner sheath
6. Polymer compound outer sheath: flame-retardant and halogen-free

*Note: Conductor twisting is not illustrated*

