



7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

ПВ1 1 x 0.75 ТУ У 31.3-00214534-056:2006

Installation wires with copper conductors, PVC compound insulation

Used for:

• fixed laying in lighting and power circuits and also for electric equipment, machines, mechanisms and machine tools installation for rated voltage up to 450 V (for networks up to 450/750), frequency up to 100 Hz or constant voltage of 1000 V

• for laying in steel pipes, hollow ducts of building structures, on trays, etc.

Manufacturing of wires in climate version F and T is possible

Fire safety code in accordance with ДСТУ 4809:2007: ПБ10000000 Products of this mark meet the requirements:

• single wire cable flame retardance

TECHNICAL SPECIFICATIONS

1

2

| Rated voltage | kV | 0.45 | |
|--|-------|----------|--|
| Number and rated area of conductors | mm² | 1 x 0.75 | |
| Insulation thikness | mm | 0.6 | |
| Operating temperature range | D° | -50 +50 | |
| Flexibility class acc. to FOCT 22483-77 | | 1 | |
| Minimum bending radius by laying | mm | 22 | |
| Outer diameter (nominal, for reference only) | mm | 2.2 | |
| Outer diameter (maximum, for reference only) | mm | 3.1 | |
| Weight (approximate) | kg/km | 10 | |
| Natasi | | | |

Notes:

When ordering it is neccesary to agree the factory length of the product with the manufacturer

CONSTRUCTION

1. Copper conductor

2. PVC compound insulation

0 1 2 3 4