



7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

ПвЭгаАкП-10 1х1000 ТУ У 31.3-00214534-017-2003



Single-core power cables with copper conductor, with XLPE, aluminium-wire armoured, with longitudinal and transverse screen sealing, with polyethylene outer sheath

Due to non-magnetic armour, cables operate at AC Technical cable requirements correspond to IEC 60502-2

Cables are used for laying:

- in places, where small mechanical impacts on cable are possible, including tensile forces
- in soil (trenches)
- in damp, partially flooded premises
- · in ground with high humidity
- in non-navigable waters
- in the air, including cable structures, if provided the additional fire protection

It is possible to manufacture cable with a segmented conductor

It is possible to manufacture cables with extruded semiconductor layer along outer sheath. Order entry example:

ПвЭгаАкП-П-10 1х1000/70 ТУ У 31.3-00214534-017-2003

An extruded semiconductor layer along outer sheath ensures the correct testing of cable line with sections of underground laying in polymer pipes.

It is possible to manufacture cables with an integrated fiber-optic module.

Order entry example:

ПвЭгаАкП-10 1х1000/70 (ОМ) ТУ У 31.3-00214534-017-2003

In conjunction with the DTS system, the integrated fiber-optic module can act as a distributed cable line temperature sensor.

It is possible to manufacture cable with sealed conductor. Order entry example: ΠβθraΑκΠ-10 1x1000/70 (г) ΤУ У 31.3-00214534-017-2003





7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua



ПвЭгаАкП-10 1x1000 ТУ У 31.3-00214534-017-2003

Single-core power cables with copper conductor, with XLPE, aluminium-wire armoured, with longitudinal and transverse screen sealing, with polyethylene outer sheath

TECHNICAL SPECIFICATIONS

| Rated voltage | kV | 10 |
|--|-------|----------------------|
| Maximum voltage | kV | 12 |
| Number and rated area of conductors | mm² | 1 x 1000 |
| Insulation thikness | mm | 3.4 |
| Minimum screen cross-section | mm² | 70 |
| Permissible short circuit current across the screen of | kA | 14.2 |
| minimum cross-section | | |
| Maximum permissible short-circuit current in core | kA | 143 |
| Permissible continious current rating * | | |
| by aerial laying in trefoil formation | А | 1460 |
| • by aerial flat laying | А | 1516 |
| by burial in trefoil formation | А | 881 |
| • by burial flat | А | 732 |
| Partial discharge factor for rated voltage, not more than | рС | 6 |
| Maximum permissible conductor temperature | | |
| Continious | °C | +90 |
| in emergency operation | °C | +130 |
| at short circuit | °C | +250 |
| Operating temperature range | °C | -60 +50 |
| Minimum bending radius by laying | mm | 1088 |
| Rated outer diameter of the cable (for reference) ** | mm | 68 |
| Cable weight (approximate) | kg/km | 12490 |
| Rated factory cable length and gross weight of the delivery on the drums *** | m, t | # 25УД-90: 611 • 9.2 |
| Nataa | | |

Notes:

When ordering it is neccesary to agree the factory length of the product with the manufacturer

* Long permissible current loads are calculated for the following conditions: conductor temperature 90 °C, air temperature 30 °C, soil temperature 20 °C, thermal resistivity of soil 1.5 °K • m/W, laying depth in the soil 0.8 m, while laying in flat formation the distance between cables in clear is equal to the cable diameter, while laying in trefoil formation cables are laid side by side, shields are earthed on both ends of the line

** The external diameter may differ from the rated up to \pm 10 %

*** Отклонение фактической массы брутто от указанного значения может составлять \pm 7 %






7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

ПвЭгаАкП-10 1х1000 ТУ У 31.3-00214534-017-2003



Single-core power cables with copper conductor, with XLPE, aluminium-wire armoured, with longitudinal and transverse screen sealing, with polyethylene outer sheath



CONSTRUCTION

- 1. Copper multiwire compact conductor
- Notes: • It is possible to manufacture cable with a segmented conductor • It is possible to manufacture cable with sealed conductor.
- 2. Lapping layer of semiconductive swellable tape
- 3. Inner extruded semiconducting layer
- 4. XLPE insulation
- 5. Outer extruded semiconducting layer
- 6. Lapping layer of semiconductive swellable tape
- 7. Copper screen
- 8. Lapping layer of semiconductive swellable tape
- 9. Alumopolymer tape
- 10. Extruded bedding of polyethylene
- 11. Aluminium-wire armour

12. Outer sheath of polyethylene or polyethylene copolymer

Note: It is possible to manufacture cable with extruded semiconductor layer along outer sheath