





7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

АПвЭВнг-150 1x1400 ТУ У 31.3-00214534-060:2011

Power cables with aluminium conductor, flame-retardant, with XLPE and with PVC compound outer sheath

For the cable of this mark correspond the foreign-made analogues:

 $A\Pi B B H \Gamma(B) (RU) \cdot A\Pi B B H \Gamma(A) (RU)$

Technical cable requirements correspond to IEC 60840

Cables are used for laying:

- in premises, tunnels, ducts, mines, dry soil and outdoor under shelter
- · in bunches

It is possible to manufacture cables with an integrated fiber-optic module.

Order entry example:

АПвЭВнг-150 1х1400/95 (ОМ) ТУ У 31.3-00214534-060:2011

In conjunction with the DTS system, the integrated fiber-optic module can act as a distributed cable line temperature sensor.

It is possible to manufacture cable with sealed conductor.

Order entry example:

АПвЭВнг-150 1х1400/95 (г) ТУ У 31.3-00214534-060:2011

Fire safety code in accordance with ДСТУ 4809:2007: ПБ130000000

Products of this mark meet the requirements:

- · single wire cable flame retardance
- · bunched cable flame retardance category B







АПвЭВнг-150 1x1400 ТУ У 31.3-00214534-060:2011

Power cables with aluminium conductor, flame-retardant, with XLPE and with PVC compound outer sheath

TECHNICAL SPECIFICATIONS

Rated voltage	kV	150
Maximum voltage	kV	170
Conductor rated area	mm²	1400
Minimum screen cross-section	mm²	35
Partial discharge factor for rated voltage, not more than	рС	6
Permissible short circuit current across the screen of	kA	14.2
minimum cross-section		
Maximum permissible short-circuit current in core	kA	132
Permissible continious current rating by aerial laying *		
in trefoil formation with double-side screen earthing	Α	1319
in trefoil formation with single-side screen earthing or	Α	1507
cross screen earthing		
plane with double-side screen earthing	Α	1240
plane with single-side screen earthing or cross screen	Α	1784
earthing		
Permissible continious current rating by burial *		
in trefoil formation with double-side screen earthing	Α	914
in trefoil formation with single-side screen earthing or	Α	1083
cross screen earthing		
plane with double-side screen earthing	Α	775
plane with single-side screen earthing or cross screen	Α	1148
earthing		
Maximum permissible conductor temperature		
Continious	° C	+90
• in emergency operation	° C	+130
at short circuit	° C	+250
Operating temperature range (in climate version NF)	° C	-50 +50
Operating temperature range (in climate version T)	° C	-25 +65
Minimum bending radius by laying	mm	1744
Data da sata di arata afilia a alala (fanasfanasa) **		100
Rated outer diameter of the cable (for reference) **	mm	109
Cable weight (approximate)	mm kg/km	12950
· · · · · · · · · · · · · · · · · · ·		

Notes:

When ordering it is neccesary to agree the factory length of the product with the manufacturer

^{*} Long permissible current loads are calculated for the following conditions: conductor temperature 90 °C, air temperature 30 °C, soil temperature 20 °C, load factor 1.0, thermal resistivity of soil 1.0 °K • m/W, laying depth in the ground 1.5 m, while laying in flat formation the distance between cables in clear is equal to the cable diameter, while laying in trefoil formation cables are laid side by side

^{**} The external diameter may differ from the rated up to \pm 10 %

^{***} Отклонение фактической массы брутто от указанного значения может составлять ± 7 %








7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

АПвЭВнг-150 1x1400 ТУ У 31.3-00214534-060:2011

Power cables with aluminium conductor, flame-retardant, with XLPE and with PVC compound outer sheath



CONSTRUCTION

- 1. Aluminium multiwire compacted conductor
- It is possible to manufacture cable with sealed conductor.
- · Conductor segment twisting is not illustrated
- 2. Lapping layer of semiconductive swellable tape
- 3. Inner extruded semiconducting layer
- 4. XLPE insulation
- 5. Outer extruded semiconducting layer
- 6. Lapping layer of semiconductive swellable tape
- 7. Copper screen

Note: It is possible to manufacture a cable with a fiber optic module built into the screen, including as a DTS system sensor

- 8. Lapping layer of glass tape
- 9. Low flammable PVC compound outer sheath