





АПвЭгП-132 1x1400 ТУ У 31.3-00214534-060:2011

Power cables with aluminium conductor, with XLPE, longitudinal screen sealing and polyethylene outer sheath

For the cable of this mark correspond the foreign-made analogues:

NA2XS2Y (DE) · NA2XS(F)2Y (DE) · A2XS2Y (DE) · A2XS(F)2Y (DE) · AI/XLPE/CWS/MDPE (GB) ·

XUHAKXS (PL) • XHAKXS (PL) • ΑΠΒΠΓ (RU) • ΑΠΒΠ (RU)

Technical cable requirements correspond to IEC 60840

Cables are used for laying:

- · in soil (trenches)
- in the air, including cable structures, if provided the additional fire protection

It is possible to manufacture cables with extruded semiconductor layer along outer sheath.

Order entry example:

АПвЭгП-П-132 1х1400/95 ТУ У 31.3-00214534-060:2011

An extruded semiconductor layer along outer sheath ensures the correct testing of cable line with sections of underground laying in polymer pipes.

It is possible to manufacture cables with an integrated fiber-optic module.

Order entry example:

АПвЭгП-132 1х1400/95 (ОМ) ТУ У 31.3-00214534-060:2011

In conjunction with the DTS system, the integrated fiber-optic module can act as a distributed cable line temperature sensor.

It is possible to manufacture cable with sealed conductor.

Order entry example:

АПвЭгП-132 1х1400/95 (г) ТУ У 31.3-00214534-060:2011











Power cables with aluminium conductor, with XLPE, longitudinal screen sealing and polyethylene outer sheath

TECHNICAL SPECIFICATIONS

| 147 | 132 |
|-------|---------------------------------------|
| | |
| | 145 |
| | 1400 |
| | 35 |
| рС | 6 |
| kA | 14.2 |
| | |
| kA | 132 |
| | |
| Α | 1319 |
| Α | 1507 |
| | |
| Α | 1240 |
| Α | 1784 |
| | |
| | |
| Α | 914 |
| Α | 1083 |
| | |
| Α | 775 |
| Α | 1148 |
| | |
| | |
| ° C | +90 |
| °C | +130 |
| °C | +250 |
| °C | -60 +50 |
| mm | 1696 |
| mm | 106 |
| kg/km | 12030 |
| m, t | # 30УД-130: 549 • 9.5 |
| | |
| | A A A A A A A A A A A A A A A A A A A |

Notes:

When ordering it is neccesary to agree the factory length of the product with the manufacturer

^{*} Long permissible current loads are calculated for the following conditions: conductor temperature 90 °C, air temperature 30 °C, soil temperature 20 °C, load factor 1.0, thermal resistivity of soil 1.0 °K·m/W, laying depth in the ground 1.5 m, while laying in flat formation the distance between cables in clear is equal to the cable diameter, while laying in trefoil formation cables are laid side by side

^{**} The external diameter may differ from the rated up to \pm 10 %

^{***} Отклонение фактической массы брутто от указанного значения может составлять $\pm\,7\,\%$










АПвЭгП-132 1x1400 ТУ У 31.3-00214534-060:2011

Power cables with aluminium conductor, with XLPE, longitudinal screen sealing and polyethylene outer sheath



CONSTRUCTION

- 1. Aluminium multiwire compacted conductor
- It is possible to manufacture cable with sealed conductor.
- · Conductor segment twisting is not illustrated
- 2. Lapping layer of semiconductive swellable tape
- 3. Inner extruded semiconducting layer
- 4. XLPE insulation
- 5. Outer extruded semiconducting layer
- 6. Lapping layer of semiconductive swellable tape
- 7. Copper screen

Note: It is possible to manufacture a cable with a fiber optic module built into the screen, including as a DTS system sensor

- 8. Lapping layer of nonwoven cloth tape
- 9. Outer sheath of polyethylene or polyethylene copolymer

Note: It is possible to manufacture cable with extruded semiconductor layer along outer sheath