



7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

ПвЭВнг-60 1x1200 ТУ У 31.3-00214534-060:2011



Power cables with copper conductor, flame-retardant, with XLPE and PVC compound outer sheath

For the cable of this mark correspond the foreign-made analogues: $\Pi_BB_{H\Gamma}(B)$ (RU) • $\Pi_BB_{H\Gamma}(A)$ (RU) Technical cable requirements correspond to IEC 60840

Cables are used for laying:

- in premises, tunnels, ducts, mines, dry soil and outdoor under shelter
- in bunches

It is possible to manufacture cables with an integrated fiber-optic module. Order entry example:

ПвЭВнг-60 1x1200/95 (ОМ) ТУ У 31.3-00214534-060:2011

In conjunction with the DTS system, the integrated fiber-optic module can act as a distributed cable line temperature sensor.

It is possible to manufacture cable with sealed conductor. Order entry example: $\Pi B \Im B H \Gamma$ -60 1x1200/95 (Γ) TY Y 31.3-00214534-060:2011

Fire safety code in accordance with ДСТУ 4809:2007: ПБ130000000 Products of this mark meet the requirements:

• single wire cable flame retardance

bunched cable flame retardance category B





7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

ПвЭВнг-60 1x1200 ТУ У 31.3-00214534-060:2011

Power cables with copper conductor, flame-retardant, with XLPE and PVC compound outer sheath

TECHNICAL SPECIFICATIONS

Rated voltage	kV	60
Maximum voltage	kV	72.5
Conductor rated area	mm²	1200
Minimum screen cross-section	mm²	35
Partial discharge factor for rated voltage, not more than	pC	6
Permissible short circuit current across the screen of	kA	10.2
minimum cross-section		10.2
Maximum permissible short-circuit current in core	kA	172
Permissible continious current rating by aerial laying *		112
in trefoil formation with double-side screen earthing	Α	1426
in trefoil formation with single-side screen earthing or	A	1721
cross screen earthing	~	1721
plane with double-side screen earthing	Α	1279
plane with single-side screen earthing or cross screen	A	2088
	A	2000
earthing Permissible continious current rating by burial *		
in trefoil formation with double-side screen earthing	۸	995
	<u> </u>	1247
 in trefoil formation with single-side screen earthing or 	А	1247
cross screen earthing	Δ	007
plane with double-side screen earthing	A	807
plane with single-side screen earthing or cross screen	А	1327
earthing		
Maximum permissible conductor temperature		
Continious	°C	+90
in emergency operation	°C	+130
at short circuit	°C	+250
Operating temperature range (in climate version NF)	°C	-50 +50
Operating temperature range (in climate version T)	°C	-25 +65
Minimum bending radius by laying	mm	1392
Rated outer diameter of the cable (for reference) **	mm	87
Cable weight (approximate)	kg/km	17770
Rated factory cable length and gross weight of the delivery	m, t	# 25УД-90: 396 • 8.6
on the drums ***		# 26УД-100: 457 • 9.9
		# 30УД-130: **** 402 • 10.0
Nataa		

Notes:

When ordering it is neccesary to agree the factory length of the product with the manufacturer

* Long permissible current loads are calculated for the following conditions: conductor temperature 90 °C, air temperature 30 °C, soil temperature 20 °C, load factor 1.0, thermal resistivity of soil 1.0 $K \cdot m/W$, laying depth in the ground 1.5 m, while laying in flat formation the distance between cables in clear is equal to the cable diameter, while laying in trefoil formation cables are laid side by side

 ** The external diameter may differ from the rated up to ± 10 %

*** Отклонение фактической массы брутто от указанного значения может составлять $\pm\,7\,\%$

**** Option delivery on not full drum






7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

ПвЭВнг-60 1x1200 ТУ У 31.3-00214534-060:2011



Power cables with copper conductor, flame-retardant, with XLPE and PVC compound outer sheath



CONSTRUCTION

- 1. Copper segmentary multiwire compact conductor
- Notes: • It is possible to manufacture cable with sealed conductor.
- Conductor segment twisting is not illustrated
 2. Lapping layer of semiconductive swellable tape
- 3. Inner extruded semiconducting layer
- 4. XLPE insulation
- 5. Outer extruded semiconducting layer
- 6. Lapping layer of semiconductive swellable tape

7. Copper screen

Note: It is possible to manufacture a cable with a fiber optic module built into the screen, including as a DTS system sensor

- 8. Lapping layer of glass tape
- 9. Low flammable PVC compound outer sheath