



7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

# ПвЭВнг-60 1x1400 ТУ У 31.3-00214534-060:2011



Power cables with copper conductor, flame-retardant, with XLPE and PVC compound outer sheath

For the cable of this mark correspond the foreign-made analogues:  $\Pi_BB_{H\Gamma}(B)$  (RU) •  $\Pi_BB_{H\Gamma}(A)$  (RU) Technical cable requirements correspond to IEC 60840

Cables are used for laying:

- in premises, tunnels, ducts, mines, dry soil and outdoor under shelter
- in bunches

It is possible to manufacture cables with an integrated fiber-optic module. Order entry example:

ПвЭВнг-60 1x1400/95 (ОМ) ТУ У 31.3-00214534-060:2011

In conjunction with the DTS system, the integrated fiber-optic module can act as a distributed cable line temperature sensor.

It is possible to manufacture cable with sealed conductor. Order entry example:  $\Pi B \Im B H \Gamma$ -60 1x1400/95 ( $\Gamma$ ) TY Y 31.3-00214534-060:2011

Fire safety code in accordance with ДСТУ 4809:2007: ПБ130000000 Products of this mark meet the requirements:

• single wire cable flame retardance

bunched cable flame retardance category B





7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

### ПвЭВнг-60 1x1400 ТУ У 31.3-00214534-060:2011

Power cables with copper conductor, flame-retardant, with XLPE and PVC compound outer sheath

# **TECHNICAL SPECIFICATIONS**

Rated voltage	kV	60
Maximum voltage	kV	72.5
Conductor rated area	mm²	1400
Minimum screen cross-section	mm²	35
Partial discharge factor for rated voltage, not more than	рС	6
Permissible short circuit current across the screen of	kA	10.2
minimum cross-section		
Maximum permissible short-circuit current in core	kA	200
Permissible continious current rating by aerial laying *		
in trefoil formation with double-side screen earthing	Α	1492
• in trefoil formation with single-side screen earthing or	Α	1846
cross screen earthing		
plane with double-side screen earthing	А	1288
plane with single-side screen earthing or cross screen	А	2234
earthing		
Permissible continious current rating by burial *		
in trefoil formation with double-side screen earthing	А	1039
in trefoil formation with single-side screen earthing or	А	1334
cross screen earthing		
plane with double-side screen earthing	А	830
plane with single-side screen earthing or cross screen	А	1426
earthing		
Maximum permissible conductor temperature		
Continious	°C	+90
<ul> <li>in emergency operation</li> </ul>	°C	+130
at short circuit	°C	+250
Operating temperature range (in climate version NF)	°C	-50 +50
Operating temperature range (in climate version T)	°C	-25 +65
Minimum bending radius by laying	mm	1456
Rated outer diameter of the cable (for reference) **	mm	91
Cable weight (approximate)	kg/km	19970
Rated factory cable length and gross weight of the delivery	m, t	# 25УД-90: 305 • 7.7
on the drums ***		# 26УД-100: **** 409 • 10.0
Notes:		

When ordering it is neccesary to agree the factory length of the product with the manufacturer

\* Long permissible current loads are calculated for the following conditions: conductor temperature 90 °C, air temperature 30 °C, soil temperature 20 °C, load factor 1.0, thermal resistivity of soil 1.0 °K  $\cdot$  m/W, laying depth in the ground 1.5 m, while laying in flat formation the distance between cables in clear is equal to the cable diameter, while laying in trefoil formation cables are laid side by side \*\* The external diameter may differ from the rated up to ± 10 %

\*\*\* Отклонение фактической массы брутто от указанного значения может составлять ± 7 %

\*\*\*\* Option delivery on not full drum






7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

# ПвЭВнг-60 1x1400 ТУ У 31.3-00214534-060:2011



Power cables with copper conductor, flame-retardant, with XLPE and PVC compound outer sheath



### CONSTRUCTION

- 1. Copper segmentary multiwire compact conductor
- Notes: • It is possible to manufacture cable with sealed conductor. • Conductor segment twisting is not illustrated
- 2. Lapping layer of semiconductive swellable tape
- 3. Inner extruded semiconducting layer
- 4. XLPE insulation
- 5. Outer extruded semiconducting layer
- 6. Lapping layer of semiconductive swellable tape

#### 7. Copper screen

Note: It is possible to manufacture a cable with a fiber optic module built into the screen, including as a DTS system sensor

- 8. Lapping layer of glass tape
- 9. Low flammable PVC compound outer sheath