





7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

# ПвЭВнг-132 1х350 ТУ У 31.3-00214534-060:2011

Power cables with copper conductor, flame-retardant, with XLPE and PVC compound outer sheath

For the cable of this mark correspond the foreign-made analogues:

 $\Pi$ вВнг(B) (RU) •  $\Pi$ вВнг(A) (RU)

Technical cable requirements correspond to IEC 60840

Cables are used for laying:

- in premises, tunnels, ducts, mines, dry soil and outdoor under shelter
- · in bunches

It is possible to manufacture cables with an integrated fiber-optic module.

Order entry example:

ПвЭВнг-132 1х350/95 (ОМ) ТУ У 31.3-00214534-060:2011

In conjunction with the DTS system, the integrated fiber-optic module can act as a distributed cable line temperature sensor.

It is possible to manufacture cable with sealed conductor.

Order entry example:

ПвЭВнг-132 1х350/95 (г) ТУ У 31.3-00214534-060:2011

Fire safety code in accordance with ДСТУ 4809:2007: ПБ130000000

Products of this mark meet the requirements:

- · single wire cable flame retardance
- · bunched cable flame retardance category B







7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

### ПвЭВнг-132 1х350 ТУ У 31.3-00214534-060:2011

Power cables with copper conductor, flame-retardant, with XLPE and PVC compound outer sheath

### **TECHNICAL SPECIFICATIONS**

Maximum voltage kV 145  Conductor rated area mm² 350  Minimum screen cross-section mm² 35  Partial discharge factor for rated voltage, not more than pC 6  Permissible short circuit current across the screen of kA 7.1  minimum cross-section  Maximum permissible short-circuit current in core kA 50.1  Permissible continious current rating by aerial laying *  • in trefoil formation with double-side screen earthing A 733  • in trefoil formation with single-side screen earthing or cross screen earthing  • plane with double-side screen earthing or cross screen  • plane with single-side screen earthing or cross screen A 886  earthing
Minimum screen cross-section mm² 35  Partial discharge factor for rated voltage, not more than pC 6  Permissible short circuit current across the screen of kA 7.1  minimum cross-section  Maximum permissible short-circuit current in core kA 50.1  Permissible continious current rating by aerial laying *  • in trefoil formation with double-side screen earthing A 733  • in trefoil formation with single-side screen earthing or cross screen earthing  • plane with double-side screen earthing or cross screen  • plane with single-side screen earthing or cross screen  A 886
Partial discharge factor for rated voltage, not more than pC 6 Permissible short circuit current across the screen of kA 7.1 minimum cross-section  Maximum permissible short-circuit current in core kA 50.1  Permissible continious current rating by aerial laying *  • in trefoil formation with double-side screen earthing A 733  • in trefoil formation with single-side screen earthing or cross screen earthing  • plane with double-side screen earthing A 753  • plane with single-side screen earthing or cross screen  A 886
Permissible short circuit current across the screen of minimum cross-section  Maximum permissible short-circuit current in core kA 50.1  Permissible continious current rating by aerial laying *  • in trefoil formation with double-side screen earthing A 733  • in trefoil formation with single-side screen earthing or cross screen earthing  • plane with double-side screen earthing A 753  • plane with single-side screen earthing or cross screen A 886
minimum cross-section  Maximum permissible short-circuit current in core kA 50.1  Permissible continious current rating by aerial laying *  • in trefoil formation with double-side screen earthing A 733  • in trefoil formation with single-side screen earthing or cross screen earthing  • plane with double-side screen earthing A 753  • plane with single-side screen earthing or cross screen A 886
Maximum permissible short-circuit current in core kA 50.1  Permissible continious current rating by aerial laying *  • in trefoil formation with double-side screen earthing A 733  • in trefoil formation with single-side screen earthing or A 767  cross screen earthing  • plane with double-side screen earthing A 753  • plane with single-side screen earthing or cross screen A 886
Permissible continious current rating by aerial laying *  • in trefoil formation with double-side screen earthing A 733  • in trefoil formation with single-side screen earthing or A 767  cross screen earthing  • plane with double-side screen earthing A 753  • plane with single-side screen earthing or cross screen A 886
<ul> <li>in trefoil formation with double-side screen earthing</li> <li>in trefoil formation with single-side screen earthing or cross screen earthing</li> <li>plane with double-side screen earthing</li> <li>plane with single-side screen earthing or cross screen</li> <li>A 753</li> <li>plane with single-side screen earthing or cross screen</li> <li>A 886</li> </ul>
<ul> <li>in trefoil formation with single-side screen earthing or cross screen earthing</li> <li>plane with double-side screen earthing</li> <li>plane with single-side screen earthing or cross screen</li> <li>A 886</li> </ul>
cross screen earthing  • plane with double-side screen earthing  • plane with single-side screen earthing or cross screen  A 886
<ul> <li>plane with double-side screen earthing</li> <li>plane with single-side screen earthing or cross screen</li> <li>A 886</li> </ul>
• plane with single-side screen earthing or cross screen A 886
·
earthing
Caramy
Permissible continious current rating by burial *
• in trefoil formation with double-side screen earthing A 581
• in trefoil formation with single-side screen earthing or A 617
cross screen earthing
• plane with double-side screen earthing A 540
• plane with single-side screen earthing or cross screen A 646
earthing
Maximum permissible conductor temperature
• Continious °C +90
• in emergency operation °C +130
• at short circuit °C +250
Operating temperature range (in climate version NF) °C -50 +50
Operating temperature range (in climate version T) °C -25 +65
Minimum bending radius by laying mm 1248
Rated outer diameter of the cable (for reference) ** mm 78
Cable weight (approximate) kg/km 9760
Rated factory cable length and gross weight of the delivery m, t # 25УД-90: 443 • 5.9
on the drums *** # 26УД-100: 631 • 8.0

#### Notes:

When ordering it is neccesary to agree the factory length of the product with the manufacturer

<sup>\*</sup> Long permissible current loads are calculated for the following conditions: conductor temperature 90 °C, air temperature 30 °C, soil temperature 20 °C, load factor 1.0, thermal resistivity of soil 1.0 °K • m/W, laying depth in the ground 1.5 m, while laying in flat formation the distance between cables in clear is equal to the cable diameter, while laying in trefoil formation cables are laid side by side

<sup>\*\*</sup> The external diameter may differ from the rated up to  $\pm$  10 %

<sup>\*\*\*</sup> Отклонение фактической массы брутто от указанного значения может составлять ± 7 %








7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

## ПвЭВнг-132 1х350 ТУ У 31.3-00214534-060:2011

Power cables with copper conductor, flame-retardant, with XLPE and PVC compound outer sheath



### **CONSTRUCTION**

- 1. Copper multiwire compact conductor
- Note: It is possible to manufacture cable with sealed conductor.
- 2. Inner extruded semiconducting layer
- 3. XLPE insulation
- 4. Outer extruded semiconducting layer
- 5. Lapping layer of semiconductive swellable tape
- 6. Copper screen

Note: It is possible to manufacture a cable with a fiber optic module built into the screen, including as a DTS system sensor

- 7. Lapping layer of glass tape
- 8. Low flammable PVC compound outer sheath