





7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

АПвЭСПнг-45 1х240 ТУ У 31.3-00214534-060:2011

Power cables with aluminium conductor, XLPE-insulated, with copper screen, lead-sheathed, with outer sheath of polymer composition, flame retardant

Technical cable requirements correspond to IEC 60840

Cables are used for laying:

- in places, where small mechanical impacts on cable are possible, including tensile forces
- in premises, tunnels, ducts, mines, dry soil and outdoor under shelter
- single laying

It is possible to manufacture cables with extruded semiconductor layer along outer sheath.

Order entry example:

АПВЭСПнг-П-45 1х240/95 ТУ У 31.3-00214534-060:2011

An extruded semiconductor layer along outer sheath ensures the correct testing of cable line with sections of underground laying in polymer pipes.

It is possible to manufacture cables with an integrated fiber-optic module.

Order entry example:

АПвЭСПнг-45 1x240/95 (ОМ) ТУ У 31.3-00214534-060:2011

In conjunction with the DTS system, the integrated fiber-optic module can act as a distributed cable line temperature sensor.

It is possible to manufacture cable with sealed conductor.

Order entry example:

АПвЭСПнг-45 1х240/95 (г) ТУ У 31.3-00214534-060:2011

Fire safety code in accordance with ДСТУ 4809:2007: ПБ101122000

Products of this mark meet the requirements:

- · single wire cable flame retardance
- toxicity class Tk1 of the combustion products of nonmetallic elements (toxicity index from 13 up to 40 g/m³)
- class μ TK1 on smoke-forming ability by smouldering of non-metallic elements (coefficient of smoke formation from 50 to 500 m²/kg)
- class ДΠκ2 on smoke-forming ability by combustion (minimum luminous flux more than 60 %)
- corrosive class $K\kappa 2$ of combustion products of non-metallic elements (the number of halogen hydrides less than 150 mg/g, pH more than 4.3, specific conductivity less than 10 μ S/mm)







7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

АПвЭСПнг-45 1х240 ТУ У 31.3-00214534-060:2011

Power cables with aluminium conductor, XLPE-insulated, with copper screen, lead-sheathed, with outer sheath of polymer composition, flame retardant

TECHNICAL SPECIFICATIONS

Maximum voltage kV 52 Conductor rated area mm² 240 Sheath thikness mm 2.2 Partial discharge factor for rated voltage, not more than pC 6 Permissible short circuit current across the screen kA 12.70 Maximum permissible short-circuit current in core kA 22.7 Permissible continious current rating by aerial laying * • in trefoil formation with double-side screen earthing A 464 • in trefoil formation with single-side screen earthing or A 477 cross screen earthing • plane with double-side screen earthing or cross screen A 565 earthing Permissible continious current rating by burial * • in trefoil formation with double-side screen earthing or A 387 • in trefoil formation with double-side screen earthing or A 399 cross screen earthing • plane with double-side screen earthing or A 399 cross screen earthing • plane with double-side screen earthing A 379 • plane with double-side screen earthing or cross screen A 416 earthing Maximum permissible conductor temperature • Continious ° C +90 • in emergency operation ° C +130
Sheath thikness mm 2.2 Partial discharge factor for rated voltage, not more than pC 6 Permissible short circuit current across the screen kA 12.70 Maximum permissible short-circuit current in core kA 22.7 Permissible continious current rating by aerial laying * · in trefoil formation with double-side screen earthing A 464 · in trefoil formation with single-side screen earthing or A 477 cross screen earthing · plane with double-side screen earthing or cross screen A 565 earthing Permissible continious current rating by burial * · in trefoil formation with double-side screen earthing or A 387 · in trefoil formation with single-side screen earthing or A 399 cross screen earthing - plane with double-side screen earthing or A 379 · plane with double-side screen earthing A 379 · plane with single-side screen earthing or Cross screen A 416 earthing Maximum permissible conductor temperature · Continious
Partial discharge factor for rated voltage, not more than Permissible short circuit current across the screen Maximum permissible short-circuit current in core RA Permissible continious current rating by aerial laying * in trefoil formation with double-side screen earthing in trefoil formation with single-side screen earthing or plane with double-side screen earthing permissible continious current rating by burial * in trefoil formation with single-side screen earthing or cross screen in trefoil formation with single-side screen earthing or cross screen in trefoil formation with double-side screen earthing or cross screen arthing Permissible continious current rating by burial * in trefoil formation with double-side screen earthing or in trefoil formation with single-side screen earthing or plane with double-side screen earthing plane with double-side screen earthing plane with single-side screen earthing or cross screen plane with single-side screen earthing or cross screen A 416 earthing Maximum permissible conductor temperature Continious C +90 in emergency operation C +130
Permissible short circuit current across the screen KA 12.70 Maximum permissible short-circuit current in core KA 22.7 Permissible continious current rating by aerial laying * • in trefoil formation with double-side screen earthing A 464 • in trefoil formation with single-side screen earthing or Cross screen earthing • plane with double-side screen earthing A 5511 • plane with single-side screen earthing or Cross screen A 565 earthing Permissible continious current rating by burial * • in trefoil formation with double-side screen earthing A 387 • in trefoil formation with double-side screen earthing or Cross screen earthing • plane with double-side screen earthing or A 399 cross screen earthing • plane with double-side screen earthing A 416 earthing Maximum permissible conductor temperature • Continious • C +90 • in emergency operation
Permissible short circuit current across the screen kA 12.70 Maximum permissible short-circuit current in core kA 22.7 Permissible continious current rating by aerial laying * • in trefoil formation with double-side screen earthing A 464 • in trefoil formation with single-side screen earthing or A 477 cross screen earthing • plane with double-side screen earthing or cross screen earthing or A 5511 • plane with single-side screen earthing or cross screen A 565 earthing Permissible continious current rating by burial * • in trefoil formation with double-side screen earthing or A 387 • in trefoil formation with single-side screen earthing or cross screen earthing • plane with double-side screen earthing or A 379 • plane with double-side screen earthing A 416 earthing Maximum permissible conductor temperature • Continious • C +90 • in emergency operation
Permissible continious current rating by aerial laying * in trefoil formation with double-side screen earthing
 in trefoil formation with double-side screen earthing in trefoil formation with single-side screen earthing or cross screen earthing plane with double-side screen earthing or cross screen plane with single-side screen earthing or cross screen plane with single-side screen earthing or cross screen permissible continious current rating by burial * in trefoil formation with double-side screen earthing in trefoil formation with single-side screen earthing or plane with double-side screen earthing plane with double-side screen earthing plane with single-side screen earthing or cross screen plane with single-side screen earthing plane with single-side screen earthing or cross screen A 416 earthing Maximum permissible conductor temperature Continious °C +90 in emergency operation °C +130
 in trefoil formation with single-side screen earthing or cross screen earthing plane with double-side screen earthing plane with single-side screen earthing or cross screen plane with single-side screen earthing or cross screen permissible continious current rating by burial * in trefoil formation with double-side screen earthing in trefoil formation with single-side screen earthing or cross screen earthing plane with double-side screen earthing plane with single-side screen earthing or cross screen plane with single-side screen earthing or cross screen A 416 earthing Maximum permissible conductor temperature C +90 in emergency operation C +130
cross screen earthing • plane with double-side screen earthing or cross screen • plane with single-side screen earthing or cross screen • plane with single-side screen earthing or cross screen earthing Permissible continious current rating by burial * • in trefoil formation with double-side screen earthing • in trefoil formation with single-side screen earthing or cross screen earthing • plane with double-side screen earthing • plane with single-side screen earthing or cross screen earthing Maximum permissible conductor temperature • Continious • C +90 • in emergency operation
 plane with double-side screen earthing plane with single-side screen earthing or cross screen pearthing Permissible continious current rating by burial * in trefoil formation with double-side screen earthing in trefoil formation with single-side screen earthing or ross screen earthing plane with double-side screen earthing plane with single-side screen earthing plane with single-side screen earthing or cross screen plane with single-side screen earthing or cross screen plane with single-side screen earthing or cross screen carthing Maximum permissible conductor temperature Continious ° C +90 in emergency operation
 plane with single-side screen earthing or cross screen earthing Permissible continious current rating by burial * in trefoil formation with double-side screen earthing in trefoil formation with single-side screen earthing or cross screen earthing plane with double-side screen earthing plane with double-side screen earthing or cross screen plane with single-side screen earthing or cross screen plane with single-side screen earthing or cross screen C +90 in emergency operation A 565 A 387 A 399 A 379 A 416 E +90 + 130
earthing Permissible continious current rating by burial * • in trefoil formation with double-side screen earthing
Permissible continious current rating by burial * • in trefoil formation with double-side screen earthing • in trefoil formation with single-side screen earthing or cross screen earthing • plane with double-side screen earthing • plane with single-side screen earthing or cross screen earthing Maximum permissible conductor temperature • Continious • in emergency operation A 387 A 399 A 379 A 416 Earthing C +90 • in emergency operation
 in trefoil formation with double-side screen earthing in trefoil formation with single-side screen earthing or cross screen earthing plane with double-side screen earthing plane with single-side screen earthing or cross screen plane with single-side screen plane with single-side screen plane with single-side screen
 in trefoil formation with single-side screen earthing or cross screen earthing plane with double-side screen earthing plane with single-side screen earthing or cross screen A 416 earthing Maximum permissible conductor temperature C +90 in emergency operation C +130
cross screen earthing • plane with double-side screen earthing • plane with single-side screen earthing or cross screen • plane with single-side screen earthing or cross screen • and the screen earthing or cross screen • Continious • C +90 • in emergency operation • C +130
 plane with double-side screen earthing plane with single-side screen earthing or cross screen plane with single-side screen earthing or cross screen A 416 earthing Maximum permissible conductor temperature C +90 in emergency operation C +130
 plane with single-side screen earthing or cross screen Plane with single-side screen earthing or cross screen Maximum permissible conductor temperature Continious C +90 in emergency operation C +130
earthing Maximum permissible conductor temperature • Continious • in emergency operation C +90 • to emergency operation
Maximum permissible conductor temperature • Continious • in emergency operation C +90 • 130
• Continious ° C +90 • in emergency operation ° C +130
• in emergency operation °C +130
• at short circuit °C +250
Operating temperature range °C -60 +50
Minimum bending radius by laying mm 1500
Rated outer diameter of the cable (for reference) ** mm 60
Cable weight (approximate) kg/km 7860
Rated factory cable length and gross weight of the delivery m, t # 22УД-60: 475 • 4.7
on the drums *** # 25УД-90: 838 • 8.2
26УД-100: **** 1040 • 10.
0

Notes:

When ordering it is neccesary to agree the factory length of the product with the manufacturer

^{*} Long permissible current loads are calculated for the following conditions: conductor temperature 90 °C, air temperature 30 °C, soil temperature 20 °C, load factor 1.0, thermal resistivity of soil 1.0 °K • m/W, laying depth in the ground 1.5 m, while laying in flat formation the distance between cables in clear is equal to the cable diameter, while laying in trefoil formation cables are laid side by side

^{**} The external diameter may differ from the rated up to \pm 10 %

^{***} Отклонение фактической массы брутто от указанного значения может составлять ± 7 %

^{****} Option delivery on not full drum








7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

АПвЭСПнг-45 1х240 ТУ У 31.3-00214534-060:2011

Power cables with aluminium conductor, XLPE-insulated, with copper screen, lead-sheathed, with outer sheath of polymer composition, flame retardant



CONSTRUCTION

- 1. Aluminium multiwire compacted conductor
- Note: It is possible to manufacture cable with sealed conductor.
- 2. Inner extruded semiconducting layer
- 3. XLPE insulation
- 4. Outer extruded semiconducting layer
- 5. Lapping layer of semiconductive swellable tape
- 6. Copper screen

Note: It is possible to manufacture a cable with a fiber optic module built into the screen, including as a DTS system sensor

- 7. Lapping layer of semiconductive swellable tape
- 8. Lapping layer of semiconductive tape
- 9. Lead sheath
- 10. Flame-retardant polymer compound outer sheath

Note: It is possible to manufacture cable with extruded semiconductor layer along outer sheath