





7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

## ПвСПу-132 1x350 ТУ У 31.3-00214534-060:2011

Power cables with copper conductor, XLPE-insulated, lead-sheathed, with reinforced outer sheath of polyethylene

Technical cable requirements correspond to IEC 60840

Cables are used for laying:

- in places, where small mechanical impacts on cable are possible, including tensile forces
- · in soil (trenches) with high corrosiveness
- · in damp, partially flooded premises
- · in wetlands
- · in non-navigable waters
- · on difficult route sections, according to the unique specification
- in the air, including cable structures, if provided the additional fire protection

It is possible to manufacture cables with extruded semiconductor layer along outer sheath.

Order entry example:

ПвСПу-П-132 1х350/95 ТУ У 31.3-00214534-060:2011

An extruded semiconductor layer along outer sheath ensures the correct testing of cable line with sections of underground laying in polymer pipes.

It is possible to manufacture cables with an integrated fiber-optic module.

Order entry example:

ПвСПу-132 1х350/95 (ОМ) ТУ У 31.3-00214534-060:2011

In conjunction with the DTS system, the integrated fiber-optic module can act as a distributed cable line temperature sensor.

It is possible to manufacture cable with sealed conductor.

Order entry example:

ПвСПу-132 1х350/95 (г) ТУ У 31.3-00214534-060:2011







ПвСПу-132 1x350 ТУ У 31.3-00214534-060:2011



Power cables with copper conductor, XLPE-insulated, lead-sheathed, with reinforced outer sheath of polyethylene

## **TECHNICAL SPECIFICATIONS**

Rated voltage	kV	132
Maximum voltage	kV	145
Conductor rated area	mm²	350
Sheath thikness	mm	2.8
Partial discharge factor for rated voltage, not more than	рС	6
Maximum permissible short-circuit current in core	kA	50.1
Permissible continious current rating by aerial laying *		
in trefoil formation with double-side screen earthing	Α	733
in trefoil formation with single-side screen earthing or	Α	767
cross screen earthing		
plane with double-side screen earthing	Α	753
plane with single-side screen earthing or cross screen	Α	886
earthing		
Permissible continious current rating by burial *		
in trefoil formation with double-side screen earthing	Α	581
<ul> <li>in trefoil formation with single-side screen earthing or</li> </ul>	Α	617
cross screen earthing		
<ul> <li>plane with double-side screen earthing</li> </ul>	Α	540
<ul> <li>plane with single-side screen earthing or cross screen</li> </ul>	Α	646
earthing		
Maximum permissible conductor temperature		
Continious	° C	+90
<ul> <li>in emergency operation</li> </ul>	° C	+130
at short circuit	° C	+250
Operating temperature range	° C	-60 +50
Minimum bending radius by laying	mm	2050
Rated outer diameter of the cable (for reference) **	mm	82
Cable weight (approximate)	kg/km	15450
Rated factory cable length and gross weight of the delivery	m, t	# 25УД-90: 420 • 8.1
on the drums ***		# 26УД-100: **** 529 • 10.0
Notes:		

#### Notes:

When ordering it is neccesary to agree the factory length of the product with the manufacturer

<sup>\*</sup> Long permissible current loads are calculated for the following conditions: conductor temperature 90 °C, air temperature 30 °C, soil temperature 20 °C, load factor 1.0, thermal resistivity of soil 1.0 °K • m/W, laying depth in the ground 1.5 m, while laying in flat formation the distance between cables in clear is equal to the cable diameter, while laying in trefoil formation cables are laid side by side

<sup>\*\*</sup> The external diameter may differ from the rated up to  $\pm$  10 %

<sup>\*\*\*</sup> Отклонение фактической массы брутто от указанного значения может составлять  $\pm\,7\,\%$ 

<sup>\*\*\*\*</sup> Option delivery on not full drum








7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

# ПвСПу-132 1x350 ТУ У 31.3-00214534-060:2011

Power cables with copper conductor, XLPE-insulated, lead-sheathed, with reinforced outer sheath of polyethylene



## CONSTRUCTION

- 1. Copper multiwire compact conductor
- Note: It is possible to manufacture cable with sealed conductor.
- 2. Inner extruded semiconducting layer
- 3. XLPE insulation
- 4. Outer extruded semiconducting layer
- 5. Lapping layer of semiconductive swellable tape
- 6. Lapping layer of semiconductive tape
- 7. Lead sheath
- 8. Strengthened polyethylene outer sheath

Note: It is possible to manufacture cable with extruded semiconductor layer along outer sheath