





7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

АПвЭгаП-220 1x1600 ТУ У 31.3-00214534-061:2008

Power cables with aluminium conductor, with XLPE, longitudinal and transverse screen sealing and polyethylene outer sheath

For the cable of this mark correspond the foreign-made analogues:

NA2XS(FL)2Y (DE) · A2XS(FL)2Y (DE) · AHXCHBMK (FI) · AI/XLPE/CWS/LW/MDPE (GB) · XRUHAKXS (PL) · AΠβΠ2Γ (RU)

Technical cable requirements correspond to IEC 62067

Cables are used for laying:

- · in soil (trenches)
- · in damp, partially flooded premises
- · in ground with high humidity
- in non-navigable waters
- in the air, including cable structures, if provided the additional fire protection

It is possible to manufacture cables with extruded semiconductor layer along outer sheath.

Order entry example:

АПвЭгаП-П-220 1x1600/95 ТУ У 31.3-00214534-061:2008

An extruded semiconductor layer along outer sheath ensures the correct testing of cable line with sections of underground laying in polymer pipes.

It is possible to manufacture cables with an integrated fiber-optic module.

Order entry example:

АПвЭгаП-220 1х1600/95 (ОМ) ТУ У 31.3-00214534-061:2008

In conjunction with the DTS system, the integrated fiber-optic module can act as a distributed cable line temperature sensor.

It is possible to manufacture cable with sealed conductor.

Order entry example:

АПвЭгаП-220 1х1600/95 (г) ТУ У 31.3-00214534-061:2008







АПвЭгаП-220 1x1600 ТУ У 31.3-00214534-061:2008

Power cables with aluminium conductor, with XLPE, longitudinal and transverse screen sealing and polyethylene outer sheath

TECHNICAL SPECIFICATIONS

Rated voltage	kV	220	
Maximum voltage	kV	252	
Conductor rated area	mm²	1600	
Minimum screen cross-section	mm²	95	
Partial discharge factor for rated voltage, not more than	рС	6	
Permissible short circuit current across the screen of	kA	19.3	
minimum cross-section			
Maximum permissible short-circuit current in core	kA	151	
Permissible continious current rating by aerial laying *			
in trefoil formation with double-side screen earthing	Α	1410	
in trefoil formation with single-side screen earthing or	Α	1594	
cross screen earthing			
plane with double-side screen earthing	Α	1316	
plane with single-side screen earthing or cross screen	Α	1831	
earthing			
Permissible continious current rating by burial *			
in trefoil formation with double-side screen earthing	Α	971	
in trefoil formation with single-side screen earthing or	Α	1157	
cross screen earthing			
plane with double-side screen earthing	Α	818	
plane with single-side screen earthing or cross screen	Α	1226	
earthing			
Maximum permissible conductor temperature			
Continious	°C	+90	
in emergency operation	°C	+130	
at short circuit	°C	+250	
Operating temperature range	°C	-60 +50	
Minimum bending radius by laying	mm	1872	
Rated outer diameter of the cable (for reference) **	mm	117	
Cable weight (approximate)	kg/km	15860	

Notes:

When ordering it is neccesary to agree the factory length of the product with the manufacturer

^{*} Long permissible current loads are calculated for the following conditions: conductor temperature 90 °C, air temperature 30 °C, soil temperature 20 °C, load factor 1.0, thermal resistivity of soil 1.0 °K • m/W, laying depth in the ground 1.5 m, while laying in flat formation the distance between cables in clear is equal to the cable diameter, while laying in trefoil formation cables are laid side by side

^{**} The external diameter may differ from the rated up to \pm 10 %








7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

АПвЭгаП-220 1x1600 ТУ У 31.3-00214534-061:2008

Power cables with aluminium conductor, with XLPE, longitudinal and transverse screen sealing and polyethylene outer sheath



CONSTRUCTION

- 1. Aluminium multiwire compacted conductor
- It is possible to manufacture cable with sealed conductor.
- · Conductor segment twisting is not illustrated
- 2. Lapping layer of semiconductive swellable tape
- 3. Inner extruded semiconducting layer
- 4. XLPE insulation
- 5. Outer extruded semiconducting layer
- 6. Lapping layer of semiconductive swellable tape
- 7. Copper screen with an integrated fiber-optic module (optional)
- 8. Lapping layer of semiconductive swellable tape
- 9. Alumopolymer tape
- 10. Outer sheath of polyethylene or polyethylene copolymer Note: It is possible to manufacture cable with extruded semiconductor layer along outer sheath