





7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

ААШп 3х95-10 ТУ У 27.3-00214534-091:2017

Power cables with aluminium conductors, with impregnated paper insulation, aluminium-sheathed, with polyethylene protection hose

Cables are used for laying:

- in soil (trenches) with high corrosiveness, as well as with vagabond currents
- · with no risk of mechanical damage in operation

TECHNICAL SPECIFICATIONS

| Rated voltage | kV | 10 |
|---|-------|-----------------|
| Number and rated area of conductors | mm² | 3 x 95 |
| Insulation thikness between conductors | mm | 5.5 |
| Insulation thikness of conductor-sheath | mm | 4 |
| Sheath thikness | mm | 1.55 |
| Permissible continious current rating * | | |
| • by aerial laying | Α | 194 |
| • by burial | Α | 192 |
| Operating temperature range | °C | -50 +50 |
| Minimum bending radius by laying | mm | 1100 |
| Level difference along the laying rout, not more than | m | 15 |
| Metal shaeth outer diameter (for reference only) | mm | 38 |
| Rated outer diameter of the cable (for reference) ** | mm | 44 |
| Cable weight (approximate) | kg/km | 2420 |
| Rated factory cable length and gross weight of the delivery | m, t | # 18: 600 • 1.9 |
| on the drums *** | | |
| | | |

Notes:

When ordering it is neccesary to agree the factory length of the product with the manufacturer

^{*} Long permissible current loads are calculated for the following conditions: air temperature plus 25 °C, soil temperature plus 15 °C, thermal resistivity of soil 1.2 °K • m/W, laying depth in the soil 0.7 m

^{**} The external diameter may differ from the rated up to \pm 10 %








7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

ААШп 3x95-10 ТУ У 27.3-00214534-091:2017

Power cables with aluminium conductors, with impregnated paper insulation, aluminium-sheathed, with polyethylene protection hose



CONSTRUCTION

- 1. Aluminium multiwire compacted conductor
- 2. Impregnated paper insulation
- 3. Cable paper bundle
- 4. Belt insulation
- 5. Conducting paper screen
- 6. Aluminium sheath
- 7. Pressed off polyethylene protection hose

Note: Conductor twisting is not illustrated