





СБлШв 3х50(ож)-1 ТУ У 27.3-00214534-091:2017

Power cables with copper conductors, with impregnated paper insulation, lead-sheathed, steel-tape armoured, with PVC-compound protection hose

Cables are used for laying:

- · in soil (trenches) with high corrosiveness without vagabond currents
- in soil (trenches) with medium corrosiveness, as well as with vagabond currents
- in fire-risk premises
- · on technological trestles
- · on special cable bridges
- · in mines, non-hazardous as for gas and dust
- · with a risk of mechanical damage and no tensile forces in operation

Fire safety code in accordance with ДСТУ 4809:2007: ΠБ100000000

Products of this mark meet the requirements:

· single wire cable flame retardance

TECHNICAL SPECIFICATIONS

Rated voltage	kV	1
Number and rated area of conductors	mm²	3 x 50
Insulation thikness between conductors	mm	1.5
Insulation thikness of conductor-sheath	mm	1.25
Sheath thikness	mm	1.15
Permissible continious current rating *		
by aerial laying	Α	195
• by burial	Α	200
Operating temperature range	°C	-50 +50
Minimum bending radius by laying	mm	480
Level difference along the laying rout, not more than	m	20
Metal shaeth outer diameter (for reference only)	mm	20
Rated outer diameter of the cable (for reference) **	mm	32
Cable weight (approximate)	kg/km	3050
Rated factory cable length and gross weight of the delivery	m, t	# 16: 370 • 1.4
on the drums ***		

Notes:

When ordering it is neccesary to agree the factory length of the product with the manufacturer

^{*} Long permissible current loads are calculated for the following conditions: air temperature plus 25 °C, soil temperature plus 15 °C, thermal resistivity of soil 1.2 °K • m/W, laying depth in the soil 0.7 m

^{**} The external diameter may differ from the rated up to \pm 10 %








7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

СБлШв 3х50(ож)-1 ТУ У 27.3-00214534-091:2017

Power cables with copper conductors, with impregnated paper insulation, lead-sheathed, steel-tape armoured, with PVC-compound protection hose



CONSTRUCTION

- 1. Copper conductor
- 2. Impregnated paper insulation
- 3. Belt insulation
- 4. Lead sheath
- 5. Single-layer plastic-tape bedding
- 6. Double steel-tape armour
- 7. Pressed PVC compound protection hose

Note: Conductor twisting is not illustrated