





7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

СБнлШнг 3х185-1 ТУ У 27.3-00214534-091:2017

Power cables with copper conductors, with impregnated paper insulation, lead-sheathed, steel-tape armoured, with low-flammable PVC-compound protection hose

Cables are used for laying:

- · in fire-risk premises
- · on special cable bridges
- · with a risk of mechanical damage and no tensile forces in operation

Fire safety code in accordance with ДСТУ 4809:2007: ПБ120000000

Products of this mark meet the requirements:

- · single wire cable flame retardance
- · bunched cable flame retardance category A

TECHNICAL SPECIFICATIONS

Rated voltage	kV	1
Number and rated area of conductors	mm²	3 x 185
Insulation thikness between conductors	mm	1.9
Insulation thikness of conductor-sheath	mm	1.55
Sheath thikness	mm	1.52
Permissible continious current rating *		
by aerial laying	Α	451
• by burial	Α	404
Operating temperature range	°C	-50 +50
Minimum bending radius by laying	mm	765
Level difference along the laying rout, not more than	m	20
Metal shaeth outer diameter (for reference only)	mm	40
Rated outer diameter of the cable (for reference) **	mm	51
Cable weight (approximate)	kg/km	9450
Rated factory cable length and gross weight of the delivery	m, t	# 18: 430 • 4.5
on the drums ***		

Notes:

When ordering it is neccesary to agree the factory length of the product with the manufacturer

^{*} Long permissible current loads are calculated for the following conditions: air temperature plus 25 °C, soil temperature plus 15 °C, thermal resistivity of soil 1.2 °K·m/W, laying depth in the soil 0.7 m

^{**} The external diameter may differ from the rated up to \pm 10 %








7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

СБнлШнг 3х185-1 ТУ У 27.3-00214534-091:2017

Power cables with copper conductors, with impregnated paper insulation, lead-sheathed, steel-tape armoured, with low-flammable PVC-compound protection hose



CONSTRUCTION

- 1. Copper multiwire compact conductor
- 2. Impregnated paper insulation
- 3. Cable paper bundle
- 4. Belt insulation
- 5. Lead sheath
- 6. Plastic-tape and glass-tape bedding
- 7. Double galvanized steel-tape armour
- 8. Pressed off low-flammable PVC compound protection hose

Note: Conductor twisting is not illustrated