



7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua



АВВГ 1x630-1 ГОСТ 16442-80,ТУ У 31.3-00214534-048:2007

Power cables with aluminium conductors, with PVC-compound insulation, with PVC-compound outer sheath

Cables are used for laying:

single laying

· in premises, dry ducts and tunnels, in corrosive environment

Fire safety code in accordance with ACTY 4809:2007: $\Pi B100000000$ Products of this mark meet the requirements:

• single wire cable flame retardance

TECHNICAL SPECIFICATIONS

Rated voltage	kV	1
Number and rated area of conductors	mm²	1 x 630
Phase insulation thikness	mm	2.8
Permissible continious current rating (AC of industrial frequency)	*	
• by aerial laying	А	744
• by burial	А	633
Permissible continious current rating (DC) *		
• by aerial laying	А	971
• by burial	А	1007
Maximum permissible conductor temperature		
Continious	°C	+70
in emergency operation	°C	+90
at short circuit	°C	+140
Operating temperature range	°C	-50 +50
Minimum bending radius by laying	mm	410
Rated outer diameter of the cable (for reference) **	mm	41
Cable weight (approximate)	kg/km	2480
Rated factory cable length and gross weight of the delivery	m, t	# 18: 660 • 2.1
on the drums ***		# 20: 1050 • 3.2
Notes:		

When ordering it is neccesary to agree the factory length of the product with the manufacturer

* Long permissible current loads are calculated for the following conditions: air temperature plus 25 °C, soil temperature plus 15 °C,

thermal resistivity of soil 1.2 °K·m/W, laying depth in the soil 0.7 m

** The external diameter may differ from the rated up to \pm 10 %






7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua



АВВГ 1x630-1 ГОСТ 16442-80,ТУ У 31.3-00214534-048:2007

Power cables with aluminium conductors, with PVC-compound insulation, with PVC-compound outer sheath



CONSTRUCTION

- 1. Aluminium multiwire compacted conductor
- 2. PVC compound insulation
- 3. PVC compound outer sheath

0 10 20 30