



7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua



АВВГ 3x50 (ож)-6 ГОСТ 16442-80,ТУ У 31.3-00214534-048:2007

Power cables with aluminium conductors, with PVC-compound insulation, with PVC-compound outer sheath

Cables are used for laying:

single laying

· in premises, dry ducts and tunnels, in corrosive environment

Fire safety code in accordance with \square CTY 4809:2007: \square E100000000 Products of this mark meet the requirements:

• single wire cable flame retardance

TECHNICAL SPECIFICATIONS

| Rated voltage | kV | 6 |
|--|-----------------|------------------|
| Number and rated area of conductors | mm ² | 3 x 50 |
| | | |
| Phase insulation thikness | mm | 3.4 |
| Permissible continious current rating (AC of industrial frequency) | * | |
| • by aerial laying | А | 126 |
| • by burial | А | 143 |
| Maximum permissible conductor temperature | | |
| Continious | °C | +70 |
| in emergency operation | °C | +90 |
| • at short circuit | °C | +160 |
| Operating temperature range | °C | -50 +50 |
| Minimum bending radius by laying | mm | 322.5 |
| Rated outer diameter of the cable (for reference) ** | mm | 43 |
| Cable weight (approximate) | kg/km | 2200 |
| Rated factory cable length and gross weight of the delivery | m, t | # 16a: 520 • 1.4 |
| on the drums *** | | # 18: 600 • 1.8 |
| | | # 20: 960 • 2.8 |
| Nataa | | |

Notes:

When ordering it is neccesary to agree the factory length of the product with the manufacturer

* Long permissible current loads are calculated for the following conditions: air temperature plus 25 °C, soil temperature plus 15 °C,

thermal resistivity of soil 1.2 $^{\circ}K^{\bullet}m/W$, laying depth in the soil 0.7 m

** The external diameter may differ from the rated up to \pm 10 %






7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua



АВВГ 3x50 (ож)-6 ГОСТ 16442-80,ТУ У 31.3-00214534-048:2007

Power cables with aluminium conductors, with PVC-compound insulation, with PVC-compound outer sheath



CONSTRUCTION

- 1. Aluminium conductor
- 2. PVC compound insulation
- 3. PVC compound bundle
- 4. PVC compound belt insulation
- 5. Lapping layer of semiconductive paper
- 6. Copper screen
- 7. PVC compound outer sheath

Note: Conductor twisting is not illustrated

0 10 20 30