



7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

АВВГнг 3х50-6 ТУ У 31.3-00214534-018-2003



Power cables with aluminium conductors, with PVC-compound insulation, with low-flammable PVC-compound outer sheath

Cables are used for laying:

- in bunches
- in premises, dry ducts and tunnels, in corrosive environment

Fire safety code in accordance with ДСТУ 4809:2007: ПБ120000000

- Products of this mark meet the requirements:
- single wire cable flame retardance
- bunched cable flame retardance category A

TECHNICAL SPECIFICATIONS

Rated voltage	kV	6
Number and rated area of conductors	mm²	3 x 50
Phase insulation thikness	mm	3.4
Permissible continious current rating (AC of industrial frequenc	y) *	
• by aerial laying	А	126
• by burial	А	143
Maximum permissible conductor temperature		
Continious	°C	+70
in emergency operation	°C	+90
at short circuit	°C	+160
Operating temperature range	°C	-50 +50
Minimum bending radius by laying	mm	337.5
Rated outer diameter of the cable (for reference) **	mm	45
Cable weight (approximate)	kg/km	2330
Rated factory cable length and gross weight of the delivery	m, t	# 16a: 480 • 1.4
on the drums ***		# 18: 550 • 1.7
		# 20: 870 • 2.7

Notes:

When ordering it is neccesary to agree the factory length of the product with the manufacturer

* Long permissible current loads are calculated for the following conditions: air temperature plus 25 °C, soil temperature plus 15 °C,

thermal resistivity of soil 1.2 $^{\circ}\!K^{\scriptscriptstyle\bullet}m/W$, laying depth in the soil 0.7 m

** The external diameter may differ from the rated up to \pm 10 %






7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

АВВГнг 3х50-6 ТУ У 31.3-00214534-018-2003

Power cables with aluminium conductors, with PVC-compound insulation, with low-flammable PVC-compound outer sheath



CONSTRUCTION

- 1. Aluminium multiwire compacted conductor
- 2. PVC compound insulation
- 3. PVC compound bundle
- 4. PVC compound belt insulation
- 5. Lapping layer of semiconductive paper
- 6. Copper screen
- 7. Low flammable PVC compound outer sheath

Note: Conductor twisting is not illustrated

0 10 20 30