



7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

# ВВГнгд 1x35-1 ТУ У 31.3-00214534-018-2003



Power cables with copper conductors, with low fire-risk PVC-compound insulation, with low fire-risk PVC-compound outer sheath

Cables are used for laying:

- in bunches
- in premises, dry ducts and tunnels, in corrosive environment
- in bunches, in crowded places

Manufacturing of cable with multiwire conductors is possible

Fire safety code in accordance with **ДСТУ** 4809:2007: ПБ123121000

Products of this mark meet the requirements:

- single wire cable flame retardance
- · bunched cable flame retardance category A
- toxicity class Tk3 of the combustion products of nonmetallic elements (toxicity index over 120 g/m<sup>3</sup>)

• class  $\[mu]T\kappa 1$  on smoke-forming ability by smouldering of non-metallic elements (coefficient of smoke formation from 50 to 500 m<sup>2</sup>/kg)

• class ДΠκ2 on smoke-forming ability by combustion (minimum luminous flux more than 60 %)

· corrosive class Kk1 of combustion products of non-metallic elements (the number of halogen hydrides less

than 150 mg/g, pH less than 4.3, specific conductivity more than 10 µS/mm)

## **TECHNICAL SPECIFICATIONS**

| kV    | 1   |
|-------|---|
| mm²   | 1 x 35  |
| mm    | 1.2   |
| cy) * |   |
| А     | 147   |
| А     | 163   |
|       |   |
| А     | 187   |
| А     | 249   |
|       |   |
| °C    | +70   |
| °C    | +80   |
| °C    | +130  |
| °C    | -50 +50   |
| mm    | 130   |
| mm    | 13  |
| kg/km | 430   |
| m, t  | # 10: 1410 · 0.7  |
|       |   |
|       | mm<br>cy) *<br>A<br>A<br>A<br>A<br>C<br>°C<br>°C<br>°C<br>°C<br>°C<br>°C<br>mm<br>mm<br>kg/km |

Notes:

When ordering it is neccesary to agree the factory length of the product with the manufacturer

\* Long permissible current loads are calculated for the following conditions: air temperature plus 25 °C, soil temperature plus 15 °C,

thermal resistivity of soil 1.2  $^\circ\!K\!\cdot\!m/W$ , laying depth in the soil 0.7 m

\*\* The external diameter may differ from the rated up to  $\pm$  10 %





7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

## ВВГнгд 1x35-1 ТУ У 31.3-00214534-018-2003

Power cables with copper conductors, with low fire-risk PVC-compound insulation, with low fire-risk PVC-compound outer sheath



### CONSTRUCTION

- 1. Copper conductor
- 2. Low fire-risk PVC compound insulation
- 3. Low fire-risk PVC compound outer sheath