



## **ПвБВнгд-FR 3x70-1 ТУ У 31.3-00214534-055:2006**

Fire-resistant power cables with copper conductors, XLPE-insulated, galvanized steel-tape armoured, with low fire-risk PVC-compound outer sheath

Cables are used for laying:


- *in bunches*
- *in premises, dry ducts and tunnels, in corrosive environment*
- *in places, where small mechanical impacts on cable are possible, including tensile forces*
- *in bunches, in crowded places*
- *power supply cable lines of NPP safety system equipment, circuits wiring of fire safety systems (fire alarm circuits, power supply of fire-fighting pumps, lightning of emergency exits and evacuation routes, smoke exhaust and blowing ventilation systems, evacuation elevators); for wiring in hospital surgical wings, emergency and equipment (current collectors) power supply circuits, operating in a fire emergency*

Manufacturing of extruded fire-resistant barrier is possible

Fire safety code in accordance with ДСТУ 4809:2007: ПБ123121080

Products of this mark meet the requirements:

- *single wire cable flame retardance*
- *bunched cable flame retardance category A*
- *toxicity class Tk3 of the combustion products of nonmetallic elements (toxicity index over 120 g/m<sup>3</sup>)*
- *class ДТк1 on smoke-forming ability by smouldering of non-metallic elements (coefficient of smoke formation from 50 to 500 m<sup>2</sup>/kg)*
- *class ДПк2 on smoke-forming ability by combustion (minimum luminous flux more than 60 %)*
- *corrosive class Kк1 of combustion products of non-metallic elements (the number of halogen hydrides less than 150 mg/g, pH less than 4.3, specific conductivity more than 10 μS/mm)*
- *flame-resistant class FE180 under fire conditions with a temperature not less than 750 °C*



## ПвБВнгд-FR 3x70-1 ТУ У 31.3-00214534-055:2006

Fire-resistant power cables with copper conductors, XLPE-insulated, galvanized steel-tape armoured, with low fire-risk PVC-compound outer sheath

### TECHNICAL SPECIFICATIONS

|  |                 |                                     |
|--|-----------------|-------------------------------------|
| Rated voltage  | kV              | 1                                   |
| Number and rated area of conductors                                      | mm <sup>2</sup> | 3 x 70                              |
| Phase insulation thickness   | mm              | 1.1                                 |
| Permissible continuous current rating (AC of industrial frequency) *     |                 |                                     |
| • by aerial laying   | A               | 265                                 |
| • by burial  | A               | 253                                 |
| Maximum permissible conductor temperature                                |                 |                                     |
| • Continuous   | °C              | +90                                 |
| • in emergency operation   | °C              | +130                                |
| • at short circuit   | °C              | +250                                |
| Operating temperature range  | °C              | -50 ... +50                         |
| Minimum bending radius by laying   | mm              | 277.5                               |
| Rated outer diameter of the cable (for reference) **                     | mm              | 37                                  |
| Cable weight (approximate)   | kg/km           | 2980                                |
| Rated factory cable length and gross weight of the delivery on the drums | m, t            | # 16a: 700 • 2.3<br># 18: 800 • 2.8 |

#### Notes:

When ordering it is necessary to agree the factory length of the product with the manufacturer

\* Long permissible current loads are calculated for the following conditions: air temperature plus 25 °C, soil temperature plus 15 °C, thermal resistivity of soil 1.2 °K·m/W, laying depth in the soil 0.7 m

\*\* The external diameter may differ from the rated up to ± 10 %

### CONSTRUCTION

1. Copper multiwire compact conductor
2. Fire-resistant barrier  
*Note: Manufacturing of extruded fire-resistant barrier is possible*
3. XLPE insulation
4. PET film winding
5. Low fire-risk PVC-compound inner sheath
6. Double galvanized steel-tape armour
7. Low fire-risk PVC compound outer sheath

*Note: Conductor twisting is not illustrated*

