



7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua



## АПвВГ 1x800-1 ГОСТ 16442-80,ТУ У 31.3-00214534-048:2007

Power cables with aluminium conductors, XLPE-insulated, with PVC-compound outer sheath

Cables are used for laying:

- single laying
- in premises, dry ducts and tunnels, in corrosive environment

Fire safety code in accordance with ДСТУ 4809:2007: ПБ10000000

- Products of this mark meet the requirements:
- single wire cable flame retardance

### **TECHNICAL SPECIFICATIONS**

Rated voltage	kV	1
Number and rated area of conductors	mm²	1 x 800
Phase insulation thikness	mm	2.6
Permissible continious current rating (AC of industrial frequence	;y) *	
• by aerial laying	А	1081
• by burial	А	773
Permissible continious current rating (DC) *		
• by aerial laying	А	1437
• by burial	А	1262
Maximum permissible conductor temperature		
Continious	°C	+90
in emergency operation	°C	+130
at short circuit	°C	+250
Operating temperature range	°C	-50 +50
Minimum bending radius by laying	mm	450
Rated outer diameter of the cable (for reference) **	mm	45
Cable weight (approximate)	kg/km	2870
Rated factory cable length and gross weight of the delivery	m, t	# 18: 550 • 2.0
on the drums ***		# 20: 870 • 3.1
Notes:		

Notes:

When ordering it is neccesary to agree the factory length of the product with the manufacturer

\* Long permissible current loads are calculated for the following conditions: air temperature plus 25 °C, soil temperature plus 15 °C,

thermal resistivity of soil 1.2  $\% \cdot m/W$ , laying depth in the soil 0.7 m

\*\* The external diameter may differ from the rated up to  $\pm$  10 %





7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua



## АПвВГ 1x800-1 ГОСТ 16442-80,ТУ У 31.3-00214534-048:2007

Power cables with aluminium conductors, XLPE-insulated, with PVC-compound outer sheath

# 

0

10

20

30

# CONSTRUCTION

- 1. Aluminium multiwire compacted conductor
- 2. XLPE insulation
- 3. PVC compound outer sheath