



7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua



АПвВГ 3x70+1x35 (ож)-1 ГОСТ 16442-80,ТУ У 31.3-00214534-048:2007

Power cables with aluminium conductors, XLPE-insulated, with PVC-compound outer sheath

Cables are used for laying:

single laying

• in premises, dry ducts and tunnels, in corrosive environment

Manufacturing of cable with multiwire conductors (main and additional one) is possible Manufacturing of cable with PVC compound belt insulation is possible

Fire safety code in accordance with ДСТУ 4809:2007: ПБ10000000

Products of this mark meet the requirements:

single wire cable flame retardance

TECHNICAL SPECIFICATIONS

Rated voltage	kV	1
Number and rated area of conductors	mm²	3 x 70 + 1 x 35
Phase insulation thikness	mm	1.1
Permissible continious current rating (AC of industrial frequency)	*	
• by aerial laying	А	203
• by burial	А	195
Maximum permissible conductor temperature		
Continious	°C	+90
in emergency operation	°C	+130
at short circuit	°C	+250
Operating temperature range	°C	-50 +50
Minimum bending radius by laying	mm	225
Rated outer diameter of the cable (for reference) **	mm	30
Cable weight (approximate)	kg/km	1030
Rated factory cable length and gross weight of the delivery	m, t	# 14: 700 • 0.9
on the drums ***		# 16a: 1120 • 1.4
Notes:		

Notes:

When ordering it is neccesary to agree the factory length of the product with the manufacturer

* Long permissible current loads are calculated for the following conditions: air temperature plus 25 °C, soil temperature plus 15 °C,

thermal resistivity of soil 1.2 $^{\circ}\!K^{\scriptstyle \bullet}$ m/W, laying depth in the soil 0.7 m

** The external diameter may differ from the rated up to \pm 10 %






7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua



АПвВГ 3x70+1x35 (ож)-1 ГОСТ 16442-80,ТУ У 31.3-00214534-048:2007

Power cables with aluminium conductors, XLPE-insulated, with PVC-compound outer sheath



CONSTRUCTION

- 1. Aluminium conductor
- 2. XLPE insulation
- 3. PVC compound bundle
- 4. PET film winding
- 5. PVC compound outer sheath

Note: Conductor twisting is not illustrated