





АПвКВ 5x16 (ож)-1 ТУ У 31.3-00214534-016-2003

Power cables with aluminium conductors, XLPE-insulated, galvanized steel-wire armoured, with PVC-compound outer sheath

Cables are used for laying:

- · single laying
- · in premises, dry ducts and tunnels, in corrosive environment
- in places, where intense tensile forces are possible (in cable lifting, in bulk, heaving, boggy, everfrost soils)

Manufacturing of cables with a different number and different design of conductors is possible Manufacturing of single-phase cables with aluminium-wire armour is possible

Fire safety code in accordance with ДСТУ 4809:2007: ΠБ100000000

Products of this mark meet the requirements:

· single wire cable flame retardance

TECHNICAL SPECIFICATIONS

Rated voltage	kV	1
Number and rated area of conductors	mm²	5 x 16
Phase insulation thikness	mm	0.7
Armor wire diameter	mm	1.4
Permissible continious current rating (AC of industrial frequen	ncy) *	
by aerial laying	Α	72
• by burial	Α	80
Maximum permissible conductor temperature		
Continious	°C	+90
at short circuit	°C	+250
Operating temperature range	°C	-50 +50
Minimum bending radius by laying	mm	208
Rated outer diameter of the cable (for reference) **	mm	26
Cable weight (approximate)	kg/km	1170
Rated factory cable length and gross weight of the delivery on the drums ***	m, t	# 14: 930 • 1.3

Notes:

When ordering it is neccesary to agree the factory length of the product with the manufacturer

^{*} Long permissible current loads are calculated for the following conditions: air temperature plus 25 °C, soil temperature plus 15 °C, thermal resistivity of soil 1.2 °K·m/W, laying depth in the soil 0.7 m

^{**} The external diameter may differ from the rated up to \pm 10 %








7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

АПвКВ 5х16 (ож)-1 ТУ У 31.3-00214534-016-2003

Power cables with aluminium conductors, XLPE-insulated, galvanized steel-wire armoured, with PVC-compound outer sheath



CONSTRUCTION

- 1. PVC compound bundle
- 2. Aluminium conductor
- 3. XLPE insulation
- 4. PET film winding
- 5. PVC compound belt insulation

6. Round galvanized steel-wire armour
Note: Manufacturing of single-phase cables with aluminium-wire armour is possible

- 7. Lapping layer of nonwoven cloth tape
- 8. PVC compound outer sheath

Note: Conductor twisting is not illustrated