







7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

ВВГ-К 3x10/10-1 ТУ У 31.3-00214534-048:2007

Power cables with copper conductors, with PVC compound insulation, with concentric conductor, with PVC compound outer sheath

Cables are used for laying:

- · single laying
- in premises, dry ducts and tunnels, in corrosive environment
- in locations, where a high level of electrical protection is required

It is possible to manufacture armoured cable

Fire safety code in accordance with ДСТУ 4809:2007: ПБ100000000

Products of this mark meet the requirements:

· single wire cable flame retardance

TECHNICAL SPECIFICATIONS

Rated voltage	kV	1
Number and rated area of conductors	mm²	3 x 10
Nominal cross-section area of concentric conductor	mm²	10
Phase insulation thikness	mm	1
Permissible continious current rating (AC of industrial frequenc	y) *	
by aerial laying	Α	63
• by burial	Α	79
Maximum permissible conductor temperature		
Continious	°C	+70
• at short circuit	°C	+160
Operating temperature range	°C	-50 +50
Minimum bending radius by laying	mm	165
Rated outer diameter of the cable (for reference) **	mm	22
Cable weight (approximate)	kg/km	750
Rated factory cable length and gross weight of the delivery	m, t	# 14: 1300 • 1.2
on the drums ***		

When ordering it is neccesary to agree the factory length of the product with the manufacturer

^{*} Long permissible current loads are calculated for the following conditions: air temperature plus 25 °C, soil temperature plus 15 °C, thermal resistivity of soil 1.2 °K • m/W, laying depth in the soil 0.7 m

^{**} The external diameter may differ from the rated up to \pm 10 %








7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

ВВГ-К 3x10/10-1 ТУ У 31.3-00214534-048:2007

Power cables with copper conductors, with PVC compound insulation, with concentric conductor, with PVC compound outer sheath



CONSTRUCTION

- 1. Copper conductor
- 2. PVC compound insulation
- 3. PVC compound belt insulation
- 4. Concentric copper conductor
- 5. Lapping layer of nonwoven cloth tape
- 6. PVC compound outer sheath

Note: Conductor twisting is not illustrated