



7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

ВВГ-К 3x240/120-1 ТУ У 31.3-00214534-048:2007



Power cables with copper conductors, with PVC compound insulation, with concentric conductor, with PVC compound outer sheath

Cables are used for laying:

- single laying
- in premises, dry ducts and tunnels, in corrosive environment
- in locations, where a high level of electrical protection is required

It is possible to manufacture armoured cable

Fire safety code in accordance with ДСТУ 4809:2007: ПБ100000000 Products of this mark meet the requirements:

• single wire cable flame retardance

TECHNICAL SPECIFICATIONS

Rated voltage	kV	1
Number and rated area of conductors	mm²	3 x 240
Nominal cross-section area of concentric conductor	mm²	120
Phase insulation thikness	mm	2.2
Permissible continious current rating (AC of industrial frequency)	*	
• by aerial laying	А	472
• by burial	А	471
Maximum permissible conductor temperature		
Continious	°C	+70
at short circuit	°C	+160
Operating temperature range	°C	-50 +50
Minimum bending radius by laying	mm	427.5
Rated outer diameter of the cable (for reference) **	mm	57
Cable weight (approximate)	kg/km	9530
Rated factory cable length and gross weight of the delivery	m, t	# 18: 340 • 3.7
on the drums ***		# 20: 550 • 5.9
Notes:		

Notes:

When ordering it is neccesary to agree the factory length of the product with the manufacturer

* Long permissible current loads are calculated for the following conditions: air temperature plus 25 °C, soil temperature plus 15 °C,

thermal resistivity of soil 1.2 $^{\circ}$ K•m/W, laying depth in the soil 0.7 m

** The external diameter may differ from the rated up to \pm 10 %






7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

ВВГ-К 3x240/120-1 ТУ У 31.3-00214534-048:2007



Power cables with copper conductors, with PVC compound insulation, with concentric conductor, with PVC compound outer sheath



10 20 40 30

CONSTRUCTION

- 1. Copper multiwire compact conductor
- 2. PVC compound insulation
- 3. PET film winding
- 4. PVC compound belt insulation
- 5. Concentric copper conductor
- 6. Lapping layer of nonwoven cloth tape
- 7. PVC compound outer sheath

Note: Conductor twisting is not illustrated