

СИПН-1 3x50+1x70 ДСТУ 4743:2007, ТУ У 27.3-00214534-066:2013

Self-supporting flame-retardant wires with polymer compound insulation, with neutral carrier non-insulated conductor

Used for laying:

- *trunks of aerial electric power lines and line branches for the rated voltage of 0.6/1 kV*
- *in air, types I and II according to ГОСТ 15150-69*

It is possible to manufacture the wire with longitudinal core sealing by water-blocking materials

Fire safety code in accordance with ДСТУ 4809:2007: ПБ1000000000

Products of this mark meet the requirements:

- *single wire cable flame retardance*

TECHNICAL SPECIFICATIONS


| | | |
|--|-----------------|--|
| Rated voltage | kV | 0.6 / 1 |
| Number and rated area of phase conductors | mm ² | 3 x 50 |
| Carrier neutral conductor rated area | mm ² | 70 |
| Phase insulation thickness | mm | 1.5 |
| Current ratings * | | |
| • <i>Continuous</i> | A | 195 |
| • <i>at short circuit (not more than 1 s)</i> | kA | 4.6 |
| Maximum permissible conductor temperature | | |
| • <i>Continuous</i> | °C | +90 |
| • <i>at short circuit (not more than 5 s)</i> | °C | +250 |
| Operating temperature range | °C | -60 ... +50 |
| Permissible temperature of laying (installation), no less than | °C | -20 |
| Minimum bending radius by laying | mm | 323 |
| Rated outer diameter of the cable (for reference) ** | mm | 32.3 |
| Weight (approximate) | kg/km | 710 |
| Rated factory cable length and gross weight of the delivery on the drums *** | m, t | # 16a: 990 • 1.0 # 18: 1130 • 1.3 # 20: 1810 • 1.9 |

Notes:

When ordering it is necessary to agree the factory length of the product with the manufacturer

* Long permissible current loads are calculated for the following conditions: ambient temperature plus 25 °C, wind speed 0.6 m/s, the intensity of solar radiation 1000 W/m²

** The external diameter may differ from the rated up to ± 10 %



СИПН-1 3x50+1x70 ДСТУ 4743:2007, ТУ У 27.3-00214534-066:2013

Self-supporting flame-retardant wires with polymer compound insulation, with neutral carrier non-insulated conductor

CONSTRUCTION

1. Aluminium multiwire compacted conductor

Note: It is possible to manufacture the wire with longitudinal core sealing by water-blocking materials

2. Multiwire aluminium-alloy compacted supporting conductor

Note: It is possible to manufacture the wire with longitudinal core sealing by water-blocking materials

3. Flame-retardant polymer compound insulation

Note: Wire lay-up is not illustrated.

