



КВВГЭнгд-FR 7х4 ТУ У 31.3-00214534-055:2006

Control screened flame-retardant flame-resistant cables with copper conductors, low fire-risk PVC compound insulation, PVC compound sheath, low smoke and gas emission

Cables are used for laying:

- *in premises, dry ducts and tunnels, in corrosive environment*
- *with no risk of mechanical damage in operation*
- *in bunches, in crowded places*
- *power supply cable lines of NPP safety system equipment, circuits wiring of fire safety systems (fire alarm circuits, power supply of fire-fighting pumps, lightning of emergency exits and evacuation routes, smoke exhaust and blowing ventilation systems, evacuation elevators); for wiring in hospital surgical wings, emergency and equipment (current collectors) power supply circuits, operating in a fire emergency*
- *with the need to protect from the effects of external electric fields*

Manufacturing of extruded fire-resistant barrier is possible

Fire safety code in accordance with ДСТУ 4809:2007: ПБ123121080

Products of this mark meet the requirements:

- *single wire cable flame retardance*
- *bunched cable flame retardance category A*
- *toxicity class Tk3 of the combustion products of nonmetallic elements (toxicity index over 120 g/m³)*
- *class ДТк1 on smoke-forming ability by smouldering of non-metallic elements (coefficient of smoke formation from 50 to 500 m²/kg)*
- *class ДПк2 on smoke-forming ability by combustion (minimum luminous flux more than 60 %)*
- *corrosive class Kк1 of combustion products of non-metallic elements (the number of halogen hydrides less than 150 mg/g, pH less than 4.3, specific conductivity more than 10 μS/mm)*
- *flame-resistant class FE180 under fire conditions with a temperature not less than 750 °C*



КВВГЭнгд-FR 7x4 ТУ У 31.3-00214534-055:2006

Control screened flame-retardant flame-resistant cables with copper conductors, low fire-risk PVC compound insulation, PVC compound sheath, low smoke and gas emission

TECHNICAL SPECIFICATIONS

Rated voltage (AC / DC)	V	660 / 1000
Number and rated area of conductors	mm ²	7 x 4
Minimum bending radius by laying	mm	120
Cable outer diameter (for reference only) **	mm	20
Cable weight (approximate)	kg/km	780
Rated factory cable length and gross weight of the delivery on the drums ***	m, t	# 12: 820 • 0.8 # 14: 1570 • 1.4

Notes:

When ordering it is necessary to agree the factory length of the product with the manufacturer

** The external diameter may differ from the rated up to ± 10 %

CONSTRUCTION

1. Copper conductor
2. Fire-resistant barrier
3. Low fire-risk PVC compound insulation
4. PET film winding
5. Low fire-risk PVC-compound inner sheath
6. Copper screen
7. Low fire-risk PVC compound outer sheath

Note: Conductor twisting is not illustrated

