



КВВГзнг 37х1 ТУ У 31.3-00214534-018-2003

Control flame-retardant cables with copper conductors, PVC compound insulation, PVC compound sheath

Cables are used for laying:

- *in premises, dry ducts and tunnels, in corrosive environment*
- *with no risk of mechanical damage in operation*
- *in bunches*

Fire safety code in accordance with ДСТУ 4809:2007: ПБ120000000

Products of this mark meet the requirements:

- *single wire cable flame retardance*
- *bunched cable flame retardance category A*

TECHNICAL SPECIFICATIONS

| | | |
|--|-----------------|-------------------------------------|
| Rated voltage (AC / DC) | V | 660 / 1000 |
| Number and rated area of conductors | mm ² | 37 x 1 |
| Minimum bending radius by laying | mm | 120 |
| Cable outer diameter (for reference only) ** | mm | 20 |
| Cable weight (approximate) | kg/km | 690 |
| Rated factory cable length and gross weight of the delivery on the drums *** | m, t | # 12: 820 • 0.7 # 14: 1570 • 1.3 |

Notes:

When ordering it is necessary to agree the factory length of the product with the manufacturer

** The external diameter may differ from the rated up to $\pm 10\%$

CONSTRUCTION

1. *Copper conductor*
2. *PVC compound insulation*
3. *Low flammable PVC compound outer sheath*

Note: Conductor twisting is not illustrated

