





7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

NYM-J 4x35 DIN VDE 0250-204

Power cables with copper conductors, PVC compound insulation, outer PVC compound sheath

Cable technical specifications conform DIN VDE 0250 p.204

Cables are used for:

- electric wiring and cable lines installation in industrial, residential and public buildings and facilities
- · laying over the plaster, inside and under plaster, in brick masonry and concrete, in pipes and ducts
- · outdoor installation, if protected from sun rays

Manufacturing of cables with light-stabilized outer sheath is possible

Fire safety code in accordance with ДСТУ 4809:2007: ΠБ100000000

Products of this mark meet the requirements:

· single wire cable flame retardance

TECHNICAL SPECIFICATIONS

| Rated voltage | kV | 0.66 |
|---|-------|-------------------|
| Number and rated area of conductors | mm² | 4 x 35 |
| Insulation thikness | mm | 1.2 |
| Permissible continious current rating * | | |
| by aerial laying (AC of industrial frequency) * | Α | 127 |
| Operating temperature range | °C | -50 +50 |
| Minimum bending radius by laying | mm | 120 |
| Rated outer diameter of the cable (for reference) ** | mm | 30 |
| Cable weight (approximate) | kg/km | 2150 |
| Rated factory cable length and gross weight of the delivery | m, t | # 14: 700 • 1.7 |
| on the drums *** | | # 16a: 1120 • 2.7 |

Notes:

When ordering it is neccesary to agree the factory length of the product with the manufacturer

^{*} Long permissible current loads are calculated for the during operation in four-wire networks with load in all the conductors at the air temperature plus 25 °C

^{**} The external diameter may differ from the rated up to \pm 10 %








7, Autogennaya Str., Kharkov, 61099, Ukraine. Phone: (+38-057) 728-1244, 728-1241. Fax: (+38-057) 728-1243, (+38-0572) 946-830 E-mail: market@yuzhcable.com.ua

NYM-J 4x35 DIN VDE 0250-204

Power cables with copper conductors, PVC compound insulation, outer PVC compound sheath



CONSTRUCTION

- 1. Copper multiwire conductor
- 2. PVC compound insulation
- 3. Extruded uncured stock inner sheath
- 4. PVC compound outer sheath

Note: Manufacturing of cables with light-stabilized outer sheath is possible

Note: Conductor twisting is not illustrated