

## ПП1нг-НF 1 x 1.5 ТУ У 31.3-00214534-056:2006

Installation wires with copper conductors, flame-retardant halogen-free polymer compound insulation

Used for:

- *fixed laying in lighting and power circuits and also for electric equipment, machines, mechanisms and machine tools installation for rated voltage up to 450 V (for networks up to 450/750), frequency up to 100 Hz or constant voltage of 1000 V*
- *for laying in steel pipes, hollow ducts of building structures, on trays, etc.*

Manufacturing of wires in climate version F and T is possible

Fire safety code in accordance with ДСТУ 4809:2007: ПБ122122000

Products of this mark meet the requirements:


- *single wire cable flame retardance*
- *bunched cable flame retardance category A*
- *toxicity class Tk2 of the combustion products of nonmetallic elements (toxicity index from 40 up to 120 g/m<sup>3</sup>)*
- *class ДТк1 on smoke-forming ability by smouldering of non-metallic elements (coefficient of smoke formation from 50 to 500 m<sup>2</sup>/kg)*
- *class ДПк2 on smoke-forming ability by combustion (minimum luminous flux more than 60 %)*
- *corrosive class Kk2 of combustion products of non-metallic elements (the number of halogen hydrides less than 150 mg/g, pH more than 4.3, specific conductivity less than 10 μS/mm)*

### TECHNICAL SPECIFICATIONS

Rated voltage	kV	0.45
Number and rated area of conductors	mm <sup>2</sup>	1 x 1.5
Insulation thickness	mm	0.8
Operating temperature range	°C	-30 ... +50
Flexibility class acc. to ГОСТ 22483-77		1
Minimum bending radius by laying	mm	29
Outer diameter (nominal, for reference only)	mm	2.9
Outer diameter (maximum, for reference only)	mm	2.8
Weight (approximate)	kg/km	19

Notes:

*When ordering it is necessary to agree the factory length of the product with the manufacturer*



## ПП1нг-НF 1 x 1.5 ТУ У 31.3-00214534-056:2006

Installation wires with copper conductors, flame-retardant halogen-free polymer compound insulation

### CONSTRUCTION

1. Copper conductor
2. Halogen-free polymer compound insulation

