



ПВЗнгд 1 x 70 ТУ У 31.3-00214534-056:2006

Installation flat wires with copper conductors, low fire-risk PVC compound insulation

Used for:

- fixed laying in lighting and power circuits and also for electric equipment, machines, mechanisms and machine tools installation for rated voltage up to 450 V (for networks up to 450/750), frequency up to 100 Hz or constant voltage of 1000 V
- electric subcircuits installation, where wire-bending are possible

Manufacturing of wires in climate version F and T is possible

Fire safety code in accordance with ДСТУ 4809:2007: ПБ123121000

Products of this mark meet the requirements:

- single wire cable flame retardance
- bunched cable flame retardance category A
- toxicity class Tk3 of the combustion products of nonmetallic elements (toxicity index over 120 g/m³)
- class ДТк1 on smoke-forming ability by smouldering of non-metallic elements (coefficient of smoke formation from 50 to 500 m²/kg)
- class ДПк2 on smoke-forming ability by combustion (minimum luminous flux more than 60 %)
- corrosive class Кк1 of combustion products of non-metallic elements (the number of halogen hydrides less than 150 mg/g, pH less than 4.3, specific conductivity more than 10 μS/mm)

TECHNICAL SPECIFICATIONS

Rated voltage	kV	0.45
Number and rated area of conductors	mm ²	1 x 70
Insulation thickness	mm	1.4
Operating temperature range	°C	-40 ... +50
Flexibility class acc. to ГОСТ 22483-77		3
Minimum bending radius by laying	mm	82
Outer diameter (nominal, for reference only)	mm	16.4
Outer diameter (maximum, for reference only)	mm	17
Weight (approximate)	kg/km	712
Rated factory cable length and gross weight of the delivery on the drums	m, t	# 10: 930 • 0.7 # 12: 1280 • 1.0

Notes:

When ordering it is necessary to agree the factory length of the product with the manufacturer



ПВЗнгд 1 x 70
ТУ У 31.3-00214534-056:2006

Installation flat wires with copper conductors, low fire-risk PVC compound insulation

CONSTRUCTION

1. *Copper multiwire conductor*
2. *Low fire-risk PVC compound insulation*

