



450301-014010000050



КУГВВЭнгд 14х0.5 **ТУ У 27.3-00214534-084:2016**

Control cables with copper conductors, with insulation and sheath made of low risk-of-fire PVC composition, with collective screen

For the cable of this mark correspond the foreign-made analogues:

КУГВВЭнг-LS (RU)

Used:

- for fixed installation of the control circuits operating at voltages up to 380 V AC 50 Hz or 500 V DC
- for multi-cable installation (acc. GOST 31565:2012) in cable channels and premises of internal electrical installations, including nuclear power stations (NPS) outside the under containment zone
- for use in systems having security class 3 (B), 3 (C) and 4 according to the classification of НП 306.2.141-2008 and НП 306.2.202-2015

Fire safety code in accordance with ДСТУ 4809:2007: ПБ123121000

Products of this mark meet the requirements:

- single wire cable flame retardance
- bunched cable flame retardance category A
- toxicity class Tk3 of the combustion products of nonmetallic elements (toxicity index over 120 g/m³)
- class ДТк1 on smoke-forming ability by smouldering of non-metallic elements (coefficient of smoke formation from 50 to 500 m²/kg)
- class ДПк2 on smoke-forming ability by combustion (minimum luminous flux more than 60 %)
- corrosive class Kк1 of combustion products of non-metallic elements (the number of halogen hydrides less than 150 mg/g, pH less than 4.3, specific conductivity more than 10 μS/mm)



КУГВВЭнгд 14х0.5 ТУ У 27.3-00214534-084:2016

Control cables with copper conductors, with insulation and sheath made of low risk-of-fire PVC composition, with collective screen

TECHNICAL SPECIFICATIONS

Rated AC voltage	V	380
Rated DC voltage	V	500
Number and rated diameter of conductors	mm ²	14 x 0.5
Operating temperature range	°C	-50 ... +60
Permissible continuous conductors temperature	°C	+70
Minimum bending radius by laying	mm	77
Cable outer diameter (for reference only) **	mm	12.8
Cable weight (approximate)	kg/km	237

Notes:

When ordering it is necessary to agree the factory length of the product with the manufacturer

** The external diameter may differ from the rated up to ± 10 %

CONSTRUCTION

1. Copper multiwire conductor
2. Low fire-risk PVC compound insulation
3. Wrapping the core with polyethylene terephthalate film
4. Collective screen of aluminium foil or metallized PET with copper contact conductor
5. Outer sheath of low risk-of-fire polyvinylchloride (PVC) composition

